

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7125-0328:167

Page 1 of 1

CATEGORY: Fire Alarm Device for the Hearing Impaired

LISTEE: Potter Electric Signal Co., 2081 Craig Road, St. Louis, MO 63146
Contact: Brad Serangeli (314) 878-4321 Fax (314) 878-7264

DESIGN: Models AS24-153075 strobe light. Model may be followed by -R or -W (red or white). To synchronize strobes use in conjunction with Model SM-3A sync module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Candela: selectable 15cd or 30cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, candela rating, and UL label.

APPROVAL: Listed as synchronized strobe light for the hearing impaired when used in conjunction with separately listed compatible fire alarm control units. For indoor use, wall or ceiling mounted in non-sleeping areas. Refer to listee's Installation Instruction Manual for details.

XLf: 7125-0587:111

08-05-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **AUGUST 5, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**